



भारत सरकार/Government of India

वाणिज्य और उद्योग मंत्रालय/Ministry of Commerce & Industry

पेट्रोलियम तथा विस्फोटक सुरक्षा संगठन (पैसो) /Petroleum & Explosives Safety Organisation (PESO)

पांचवा तल, ए-ब्लॉक, सी.जी.ओ.कॉम्प्लेक्स, सेमिनरी हिल्स

नागपुर- 440006

5th Floor, A-Block, CGO Complex, Seminary Hills,

Nagpur - 440006

ई-मेल:/E-mail : explosives@explosives.gov.in

फोन / फ़ैक्स नंबर:/Phone/Fax No : 0712 -2510248,

Fax-2510577

अनुज्ञप्ति सं./No : S/HO/MN/03/5(S94397)

दिनांक/Dated : 02/07/2025

सेवा में/To,

M/s. KANGLA ENERGY SOLUTIONS PVT. LTD.,
Mr. Th. Budhi Singh, IED-II, 30-B-74/2, Malom Tuli,
Makha Leikai, Imphal West, Manipur, India, 795140,
Malom Tuliyaime,
Makha Leikai,
Taluka: Makha Leikai,
District: WEST IMPHAL,
State: Manipur
PIN: 795140

विषय :/Sub : Plot No, Patta No. 134(New), Dag No.210, Sagolmang Khewa Company Tahsil Sagolmang, Sagolmang Khewa Company Tahsil Sagolmang, Sawombung, Taluka: Sawombung, District: EAST IMPHAL, State: Manipur, PIN: 795114 स्थित LPG, गैस के संपीडित पात्र / पात्रों में भंडारण के लिए स्थिर एवं गतिशील दाब पात्र (अज्वलित) नियम, 2016 के अधीन स्वीकृत अनुज्ञप्ति संख्या S/HO/MN/03/5 के स्थानांतरण संबंध में /Storage of LPG gas in pressure vessels at Plot No, Patta No. 134(New), Dag No.210, Sagolmang Khewa Company Tahsil Sagolmang, Sagolmang Khewa Company Tahsil Sagolmang, Sawombung, Taluka: Sawombung, District: EAST IMPHAL, State: Manipur, PIN: 795114 - Licence No : S/HO/MN/03/5 grant in form LS-1A of SMPV(U) Rules, 2016-Transfer of Licence Regarding

महोदय/Sir(s),

कृपया आपके दिनांक : 06/06/2025 के पत्र संख्या: OIN1934447 का संदर्भ ग्रहण करें I/Please refer to your application No.OIN1934447 dated 06/06/2025 .

अनुज्ञप्ति संख्या : S/HO/MN/03/5 का फॉर्म एलएस 1 ए / बी में आपके नाम पर व्यवस्थित रूप से स्थानांतरित किया गया है।
Licence Number: S/HO/MN/03/5 in Form LS1A/B is sent herewith duly transferred in your name.

दिनांक 30/09/2027 . से आगे अनुज्ञप्ति नवीनीकरण हेतु उपरोक्त नियम के प्रावधानों का पालन किया जाए। विलंब शुल्क से बचने हेतु शुल्क के साथ मूल अनुज्ञप्ति तथा अन्य दस्तावेज अधिकतम दिनांक : 30 सितंबर, 2027 तक The Jt. Chief Controller of Explosives, Guwahati Circle, Guwahati में जरूर पहुंच जाने चाहिए।

The renewal application along with fees, Original licence and other documents shall reach in the Office of The Jt. Chief Controller of Explosives, Guwahati Circle, Guwahati, latest by 30th September,2027 to avoid late fee.

भवदीय/Yours faithfully,

((बासुदेव बसाक)

(Basudev Basak)

उप मुख्य विस्फोटक नियंत्रक
Dy. Chief Controller of Explosives
कृते मुख्य विस्फोटक नियंत्रक
For Chief Controller of Explosives
नागपुर/Nagpur

Copy forwarded to :-

1. The Additional District Magistrate, EAST IMPHAL(Manipur) with reference to his NOC No 1/DC(IE)-NOC/2021 Dated 29/12/2021
2. Jt. Chief Controller of Explosives, Guwahati, KAMRUP. A Copy of the licence along with approved plan is enclosed.
3. M/s. KANGLA GAS SOLUTIONS PVT. LTD., KEISAMPAT THIYAM

LEIKAI, IMPHAL WEST, , WEST IMPHAL, KEISAMPAT THIYAM
LEIKAL,KEISAMPAT THIYAM LEIKAL, Manipur, 795001

**For Chief Controller of Explosives
Nagpur**

(For more information regarding status,fees and other details please visit our website <http://peso.gov.in>)

Note:-This is system generated document does not require physical signature.

**FORM LS-1A/प्ररूप - एलएस-1क**

(See Rules 50, 51, 54 and 55)/(नियम 50, 51, 54 और 55 देखें)

Licence to Store Compressed gas in pressure vessel or vessels**दाब पात्र या पात्रों में संपीड़ित गैस भण्डारकरण के लिए अनुज्ञप्ति**अनुज्ञप्ति सं/Licence No. : **S/HO/MN/03/5(S94397)**फीस रुपए/Fee Rs. **50000/-** per year/प्रति वर्ष

Licence is hereby granted to **KANGLA ENERGY SOLUTIONS PVT. LTD., Mr. Th. Budhi Singh, IED-II, 30-B-74/2, Malom Tuli, Makha Leikai, Imphal West, Manipur, India, 795140, Malom Tuliya, Makha Leikai, Taluka: Makha Leikai, District: WEST IMPHAL, State: Manipur PIN: 795140** valid only for the storage of compressed gas in 2 Number(s) of pressure vessels as indicated below in the licensed premises described below and shown in the plan No. **S/HO/MN/03/5(S94397)** dated **02/07/2025** subject to the provisions of the Indian Explosives Act, 1884 (4 of 1884) and the rules made thereunder and to the further conditions of this licence.

श्री **KANGLA ENERGY SOLUTIONS PVT. LTD., Mr. Th. Budhi Singh, IED-II, 30-B-74/2, Malom Tuli, Makha Leikai, Imphal West, Manipur, India, 795140, Malom Tuliya, Makha Leikai, Taluka: Makha Leikai, District: WEST IMPHAL, State: Manipur PIN: 795140** को नीचे वर्णित अनुज्ञप्त परिसरों में और रेखांकन संख्या **S/HO/MN/03/5(S94397)** dated **02/07/2025** में भारतीय विस्फोटक अधिनियम, 1884 (1884 का 4) और उसके अधीन बनाए गए नियमों तथा इस अनुज्ञप्ति की अन्य शर्तों पर 2 दाब पात्र / पात्रों में संपीड़ित गैस के भण्डारण के लिए अनुज्ञप्ति मंजूर की जाती है।

यह अनुज्ञप्ति 30 सितंबर 2027 तक प्रवृत्त रहेगी।

The Licence shall remain in force till the **30th September 2027**.

Vessel No./वेसल नंबर	Name of Gas/गैस का नाम	State of Gas/गैस की स्थिति	Water Capacity in cubic meter/जल क्षमता (घ.मी.)	Max. working Pre.(kg/cm ²)/अधिकतम वर्किंग प्रेशर	Quantity Granted in kgs(Liquified gas)/किलोग्राम में जारी मात्रा (लिक्विफाईड गैस)
KMV-AG-02	LPG	Liquified	42.60	14.5	20033
KMV-AG-023	LPG	Liquified	42.60	14.5	20033
Total Water capacity			85.20		

February 17, 2022

For Chief Controller of Explosives
HQ, Nagpur
कृते मुख्य विस्फोटक नियंत्रक
नागपुर

DESCRIPTION AND LOCATION OF THE LICENSED PREMISES/अनुज्ञप्त परिसर का विवरण और अवस्थिति

The licensed premises, the layout boundaries and other particulars of which are shown in the attached approved plan No. **S/HO/MN/03/5** dated **02/07/2025** are situated at **SawombungSagolmang Khewa Company Tahsil Sagolmang** and consists of 2 Number(s) vessel(s) for storage of :/अनुज्ञप्त परिसर, प्रदर्शित सीमा और अन्य विवरण जो सलग अनुमोदित रेखाचित्र क्र. **S/HO/MN/03/5** दिनांक **02/07/2025** में दर्शाए गए है **SawombungSagolmang Khewa Company Tahsil Sagolmang** पर स्थित है और इसमें 2 वेसल सम्मिलित है।

a) Flammable/Corrosive/Toxic Gases :/ज्वलनशील / संक्षारक / विषैली गैसों: **LPG**

b) Non-Toxic Gases :/अविषैली गैसों :

and is situated at PlotNo : **Patta No. 134(New), Dag No.210, Village/Town : SawombungSagolmang Khewa Company Tahsil Sagolmang, Police Station : Sagolmang, District : EAST IMPHAL, State : Manipur, Pin : 795114.**/प्लॉट संख्या PlotNo : **Patta No. 134(New), Dag No.210, गांव या नगर : SawombungSagolmang Khewa Company Tahsil Sagolmang, पुलिस थाना : Sagolmang, जिला : EAST IMPHAL, राज्य : Manipur, Pin : 795114** में स्थित है।**SPACE FOR ENDORSEMENT OF RENEWALS/नवीकरण के पृष्ठांकन के लिए स्थान**

	Date of Renewal/नवीकरण की तारीख	Date of Expiry/अनुज्ञप्ति की समाप्ति की तारीख	Signature and stamp of the licensing authority/अनुज्ञापन प्राधिकारी के हस्ताक्षर और कार्यालय की मुद्रा
This licence shall be renewable without any concession in fee for			

<p>three years in the absence of contravention of the provision of the Indian Explosives Act, 1884, or the Static and Mobile Pressure Vessles (Unfired) Rules, 2016, framed thereunder or of the conditions of the licence./अनुज्ञप्ति, भारतीय विस्फोटक अधिनियम, 1884 या उसके अधीन बनाए गए स्थिर एवं गतिशील दाब पात्र (अज्वलित) नियम, 2016 या इस अनुज्ञप्ति की शर्तों का उल्लंघन न होने की दशा में, फीस में बिना किसी छूट के तीन वर्ष तक नवीकृत की जाएगी।</p>	<p>22/09/2022</p>	<p>30/09/2027</p>	<p>Dinesh Singh DCE For Jt. Chief Controller of Explosives Assam</p>
---	-------------------	-------------------	---

This licence is liable to be cancelled if the licenced premises are not found conforming to the description and conditions attached hereto and contravention of any of the rules and conditions under which this licence is granted and the holder of this licence is also punishable with imprisonment for the term which may extend to two years or with fine which may extend to three thousand rupees or with both./यदि निरीक्षण के समय अनुज्ञप्त परिसर इससे उपाबद्ध विवरण और शर्तों के अनुरूप नहीं पाया जाता है और जिन नियमों और शर्तों के अधीन यह अनुज्ञप्ति मंजूर की गई है, उनमें से किसी का उल्लंघन होता है तो उस दशा में यह अनुज्ञप्ति रद्द की जा सकती है और अनुज्ञप्ति का धारक कारावास से, जिसकी अवधि दो वर्ष तक की हो सकेगी, या जुर्माने से, जो तीन हजार रुपये तक का हो सकेगा, या दोनों से दण्डनीय भी होगा।

Note:-This is system generated document does not require physical signature.

Conditions of FORM LS-1A

License No. :S/HO/MN/03/5(S94397)

1. The licensed premises shall conform to the description of location and facilities and to the approved plan, as mentioned on the body of the licence.
2. The licensed premises shall have prominently marked thereon the number of the licence held for it.
3. The emergency telephone numbers of local fire service, police and the principal marketing company or supplier of the compressed gas, and emergency instructions shall be conspicuously displayed in the licensed premises.
4. The licensed premises shall not be used for any purpose other than the purpose for which the licence is granted.
5. The compressed gas shall be stored only in the vessels specified in the licence and shown in the approved plan attached hereto.
6. The storage vessel shall at all times maintain requisite safety distance from any other facility, building, boundary, fencing or protected works as specified in appropriate Table specified in rule 22.
7. A suitable hard stand for parking of the vehicle during loading or unloading of any compressed gas shall be provided. The following minimum safety distances shall be provided between the centre of the hard stand and the storage vessel or boundary line of installation; as well as between the loading or unloading points and storage vessel or boundary line of installation as specified under item (ii) of sub-rule 5 of Rule 27.
8. All fitments of the vessel shall be maintained in good operating condition.
9. No alteration of the position of the vessel and no replacement of the vessel shall be effected except with the previous sanction, in writing, of the licensing authority as provided in the rules.
10. Every vessel before being repaired or exhumed shall be made free of compressed gas and thoroughly cleaned in a safe manner. When a vessel is opened for cleaning or repairs, no lamp of any description either ordinary or electric, electric cables or fans and no articles, appliances or equipment capable of igniting flammable vapours shall be brought near the vessel.
11. No person shall cause to repair or repair either by the use of fire, welding, hot riveting or brazing any vessel used for the storage of flammable gas unless it has been thoroughly cleaned and gas-freed or otherwise prepared for safely carrying out such hot work and certified in writing, by a competent person, to have been so prepared. Where the vessel has been certified as gas-free, the certificate shall be preserved by the licensee for a period of not less than three months and produced to the licensing authority on demand.
12. No person shall enter any vessel used for the storage of a toxic or corrosive gas unless he is adequately protected by means of protective clothing, gas masks and such other equipments as may be required in the specific case.
13. Compressed gas shall be filled into or removed from the vessel through designated pipes of required specification and through transfer facilities shown in the approved plan.
14. The vessel shall not be filled between the hours of sunset and sunrise, unless adequate lighting of approved type is provided and except in such manner and such other condition or conditions as are specifically endorsed on the licence by the licensing authority.
15. All operations in the licensed premises shall be carried out by persons competent in such operation. Every person managing or employed on or in connection with the licensed premises shall abstain from any act whatsoever which tends to cause fire or explosion and which is not reasonably necessary and to the best of his ability, shall prevent any other person from doing such act.
16. The licensee shall provide for each licensed premises a minimum of two portable foam type or dry chemical type fire extinguishers of 9 kg. capacity each, which shall be kept ready at convenient location for immediate use in the event of any fire in addition to other fire fighting or other mitigating facilities required for flammable or toxic gases.
17. All valves in the premises must be permanently marked in a manner clearly indicating the direction of opening and shutting the valve.
18. Free access to the licensed premises shall be given at all reasonable times to any of the officers specified in

rule 70 and every facility shall be afforded to such officer for ascertaining that the rules and the conditions of this licence are duly observed.

19. If the licensing authority calls upon the holder of a licence by a notice in writing to execute any repairs in the licensed premises which are, in the opinion of such authority, necessary for the safety of the premises, the holder of the licence shall execute the repairs within such period as may be specified in the notice.
20. Every vessel shall be outside any building and shall be supported on well designed calculations.
21. No artificial light capable of igniting flammable vapour shall at any time be present within nine meters of the vehicle and the loading or unloading points during the transfer of the compressed gas and no person engaged in such transfer shall smoke.
22. All electrically equipment such as motors switches, starters used for transfer of liquefied petroleum gas shall be of flameproof construction conforming to IS/IEC 60079-1 to 11 or of a type approved by the Chief Controller.
23. Smoking, naked lights, lamps, source of fire or any other stimulant capable of igniting flammable vapours shall not be allowed inside the premises. Every person managing or employed on or in connection with licensed premises shall abstain from any act whatsoever which tends to cause fire or explosion and which is not reasonably necessary and to the best of his ability, shall prevent any other person from doing such act.
24. Any accident, fire ,explosion or untoward incident occurred within the licensed premises shall be immediately reported to the Chief Controller of Explosives, Controller, nearest police station and District Magistrate by quickest mode of communication.

For The Chief Controller of Explosives, Nagpur (M.S.)